

November 19, 2024

Addendum #1 - Request for Information (RFI)

**Attn: Bidding firms for the FIRE SYSTEMS: Annual Inspections, Testing & Maintenance
BID # ITB-AP-53-0-2024/CB**

The purpose of this document is to address Requests for Information for bidding purposes.

1. Are any previous testing reports available for review?

- The 2022 Fire System Inspection Reports for all Asbury Park Housing Authority locations and the 2024 Inspection Reports for Lincoln Village are attached to this Addendum as Attachment #1 and Attachment #2.


2. Are copies of any HUD requirements related to this bid available for review?

- See Attachment #3 which contains form HUD-5369 (Instructions to Bidders) and HUD-5369-B (Instructions to Offerors Non-Construction).

3. What are the required inspection frequencies for the various systems covered under this contract?

- The frequency of inspections shall not be less than the minimum values indicated in NFPA 72 and NFPA 25. Additional inspections required by local authority (state and/or city) are also covered under this contract.

Respectfully,
Edwin McDonald
Director of Maintenance

732.774.2660 

732.774.8623 

1000 ½ Third Avenue Asbury Park, NJ 07712 